


Total tank capacity inlet septic excluding baffles	7,800 litres
Primary Capacity 1	1,670 litres
Primary Capacity 2	880 litres
Collection Well	5,020 litres
Total Volume	7,570 litres
Main baffle thickness	50mm
Secondary baffle thickness	40mm



Inspection holes are located over inlet & outlet of septic chambers

Manhole centres are 570mm in diameter

Cut out in secondary baffle is 100mm x 150mm and located 700mm from base of tank

Main and secondary baffles integrated

Lifting pins 600mm from top of tank on sides

75mm wide integrated collar at base of tank

Suction line to be installed by plumber

APPROVED

15 SEP 2015

Specification for
NSW MINISTRY OF HEALTH

Name	
Installation Address	
Number of Persons	

7500 litre Combined Septic Tank & Collection Well

All Collection Wells are manufactured to comply with Australian Standards AS/NZS 1546.1:2008

COLLECTION WELLS manufactured by Highland Concrete Tanks PO Box 1158, MITTAGONG NSW 2575 Phone: 02 48898 8288 Fax: 02 4889 8566 www.highlandtanks.com.au	Highland Tanks Pty Ltd ABN 93 090 907 725 trading as Highland Concrete Tanks AS/NZS 1546.1:2008 Licence SMK20582	Drawing No. HCT3
Designed: D.W. Rebbeck	Drawn By: D.W. Rebbeck	Date: 28/05/2012
HCT3D 54 Revision 1 31/08/2012	NOT TO SCALE	